



CERTIFICATE OF REGISTRATION

This is to certify that

**Kingsbury Group (Kingsbury Builders Merchants, Kingsbury
Joinery, Kingsbury Construction, Kingsbury Maintenance)**

Cranborne Industrial Estate
Cranborne Road
Potters Bar
EN6 3JN

Meets the requirements of the BM TRADA **Q-Mark Fire Door Manufacture** scheme to
STD006

Steve Roberts
Product Certification Operations Manager
For and on behalf of BM TRADA

Certificate Number

1042

Date of Initial Certification

02/10/2017

Date of Last Issue

26/10/2023

Date of Expiry

01/10/2026

BM TRADA is a trading name of Warringtonfire Testing and Certification Limited, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA, UK
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com

Registration Schedule

Branch Kingsbury Group (Kingsbury Builders Merchants, Kingsbury Joinery, Kingsbury Construction, Kingsbury Maintenance)	Address Cranborne Industrial Estate Cranborne Road Potters Bar EN6 3JN
---	---

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Type	FoA Report	Rev	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	FoA Standard
Fire	WF399442	A	Kingsbury Group	Field of Application for Kingsbury Doorsets 30 minutes fire resistance (Falcon Strebord® and Stredor® based timber entrance doorset) (Glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			
Fire	WF420601	C	Kingsbury Group	Field of Application for Kingsbury Doorsets 60 minutes fire resistance (Falcon Stredor® based timber entrance doorset) (Glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			

Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Type	FoA Report	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	FoA Standard
Fire	Chilt/A12137	Falcon Timber Limited	STREbord® 35 doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF380559	Falcon Timber Limited	STREbord® 35+ doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	Chilt/A02066	Falcon Timber Limited	STREbord® 44 door assemblies for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	Chilt/A09104	Falcon Timber Limited	STREbord® 44 Panelled doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	Chilt/A02066	Falcon Timber Limited	STREbord® 54 door assemblies for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	BMT/CNA/F15159	Falcon Timber Limited	STREdor® 44 doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF377027	Falcon Timber Limited	STREdor® 54 Doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF377027	Falcon Timber Limited	STREdor® 54 Doorsets for 60 Minutes Fire Resistance (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	Chilt/A10152	Falcon Timber Limited	STREbord® 54 Panelled Range of Doorsets using STREbord® 54 Panelled Door Blanks in Timber Based Door Frames 60 Minutes Fire Resistance (Unglazed only)	60min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF407090	Falcon Timber Limited	STREbord® 44 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF407090	Falcon Timber Limited	STREbord® 54 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF407090	Falcon Timber Limited	STREdor® 44 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF407090	Falcon Timber Limited	STREdor® 54 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF427764	Falcon Timber Limited	STREbord® 54 Fire Resisting Doorsets for 60 minutes fire resistance (Front Entrance Doorsets) (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	WF427764	Falcon Timber Limited	STREdor® 54 Fire Resisting Doorsets for 60 minutes fire resistance (Front Entrance Doorsets) (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-			N/A

Test Reports

Test reports cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
WF 372131 (Doorset A)	Kingsbury Group	FD 30 Fire Doorset (Unglazed)	30min	BS 476 Pt22
WF 372131 (Doorset B)	Kingsbury Group	FD 30 Fire Doorset incorporating sidelight, sidepanel, fanlight and overpanel (Glazed)	30min	BS 476 Pt22
WF 403429 (Doorset A)	Kingsbury Group	FD 60 Fire Doorset (Glazed)	60min	BS 476 Pt22